



NOTES:

1. NON-SHRINK GROUT SHALL HAVE THE FOLLOWING CHARACTERISTICS:
3000 PSI MIN. COMPRESSIVE STRENGTH AT 28 DAYS, MIN. 6 SACKS OF CEMENT PER CUBIC YARD
AND SLUMP AT 1 TO 4 INCHES. ALL MATERIAL SHALL CONFORM TO SSPWC SECTION 202.
2. AN AGENCY-APPROVED FORM OF SEAL OR WATER STOP IS REQUIRED ON ALL SANITARY SEWER
INSTALLATIONS AND IN OTHER APPLICATIONS AS REQUIRED BY THE CITY TO PROVIDE A WATERTIGHT
CONNECTION.
3. A RESILIENT FLEXIBLE CONNECTOR INSTALLED IN ACCORDANCE WITH STD. CONNECTION DETAIL A OF
STD. DETAIL R-223 (311) MAY BE USED TO SATISFY THE REQUIREMENTS OF NOTE 2 ABOVE.
4. ALL PIPE OPENINGS TO NEW MANHOLES MUST BE EITHER CAST-IN-PLACE OR PRE-FORMED AND
PIPE OPENINGS TO EXISTING MANHOLES MUST BE CORE DRILLED.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION	RENO
1	ELIM. COUPLING	06/01	CONCRETE SANITARY SEWER PIPE TO MANHOLE	DRAWING NO.	
				R-219 311	
				DATE	PAGE
APPROVED BY : S.V.		06/01		08/00	224